

PROSJEČNE VRIJEDNOSTI POKAZATELJA KVALITETE VODE IZ GRADSKOG VODOVODA

2020. god.

Uzorci su analizirani u ovlaštenom laboratoriju.	Fizikalno-kemijski i pokazatelji															Mikrobiološki pokazatelji					
	Temperatura °C	Mutnoća NTU jedinice	Boja mg/l Pt/Co skale	Miris bez	Okus bez	pH pH jedinice	Elektrovodljivost µS/cm pri 25 °C	Utrošak KMnO4 mg/l O2	Slobodni klor mg/l Cl2	Željezo µg/l Fe	Mangan µg/l Mn	Kloridi mg/l Cl	Nitriti mg/l NO2	Nitrati mg/l NO3	Amonij mg/l NH4	Broj kolonija 36 °C cfu / 1 ml	Broj kolonija 22 °C cfu / 1 ml	Escherichia coli cfu / 100 ml	Ukupni koliformi cfu / 100 ml	Enterokoki cfu / 100 ml	Pseudomonas aeruginosa cfu / 100 ml
MDK	25	4	20	bez	bez	6,5-9,5	2500	5	0.5	200	50	250	0.5	50	0.5	100	100	0	0	0	0
PROSIJEK - 2020.	15.85	0.77	4.04	bez	bez	7.56	436.5	0.59	0.118	34.39	18.65	5.85	0.13	1.51	0.11	2.63	1.89	0	0	0	0
SIJEČANJ	10.32	0.80	4	bez	bez	7.59	432.32	0.83	0.12	36.32	14.32	5.64	0.13	1.40	0.11	5.32	4.21	0	0	0	0
VELJAČA	11.11	0.72	4	bez	bez	7.58	436.58	0.64	0.11	30.00	14.74	6.26	0.13	1.40	0.13	0.63	0.11	0	0	0	0
OŽUJAK	12.21	0.72	4.05	bez	bez	7.55	433.74	0.54	0.09	32.11	17.21	6.13	0.13	1.49	0.11	0.74	0.05	0	0	0	0
TRAVANJ	14.11	0.72	4	bez	bez	7.61	432.00	0.56	0.10	31.05	19.79	5.88	0.13	1.65	0.11	5.95	1.32	0	0	0	0
SVIBANJ	15.53	0.78	4	bez	bez	7.52	434.63	0.55	0.08	33.68	17.58	6.06	0.13	1.47	0.11	3.89	0.79	0	0	0	0
LIPANJ	17.66	0.83	4.16	bez	bez	7.52	437.21	0.53	0.11	38.42	16.37	5.98	0.13	1.59	0.11	4.21	4.37	0	0	0	0
SRPANJ	20	0.72	4	bez	bez	7.56	438.11	0.63	0.12	42.63	22.21	5.65	0.13	1.52	0.11	2.63	1.32	0	0	0	0
KOLOVOZ	21.32	1.03	4	bez	bez	7.50	440.05	0.55	0.08	42.63	20.00	5.84	0.13	1.50	0.11	6.58	7.00	0	0	0	0
RUJAN	20.89	0.72	4	bez	bez	7.53	440.05	0.53	0.11	31.58	19.00	5.76	0.13	1.55	0.11	1.16	0.42	0	0	0	0
LISTOPAD	17.79	0.72	4.32	bez	bez	7.50	432.05	0.63	0.17	32.63	17.89	5.08	0.13	1.58	0.11	0.26	2.79	0	0	0	0
STUDENI	15.89	0.72	4	bez	bez	7.60	439.89	0.56	0.18	30.00	20.47	5.77	0.13	1.54	0.11	0.00	0.00	0	0	0	0
PROSINAC	13.42	0.72	4	bez	bez	7.68	440.84	0.56	0.16	31.58	24.26	6.11	0.13	1.47	0.11	0.16	0.37	0	0	0	0